

Sika Corporation

Construction

January 12, 2009

Dear Sir/Madam:

Sika has identified a quality issue in the Part A (epoxy resin) component of batches of Sikadur AnchorFix-3 and AnchorFix-4 manufactured in or after January 2007. While Sika has received no complaints from any end-users of the products, and not all batches manufactured during this time frame are affected, Sika is nonetheless, out of an abundance of caution, recalling all unused cartridges of AnchorFix-3 and AnchorFix-4 that were manufactured in or after January 2007. If you have any such unused cartridges of AnchorFix-3 or AnchorFix-4, please contact Michelle Alvarado at 201-508-6702. Sika will either issue you a material credit for all returned cartridges or will replace your unused cartridges of AnchorFix-3 or AnchorFix-4 with Sikadur AnchorFix-2.

Sikadur AnchorFix-2 is an epoxy acrylate anchoring adhesive that can be used in similar applications as AnchorFix-3 and AnchorFix-4.

As with all anchoring situations, please contact a design professional prior to use.

If you have used, or are aware that your customers have used, Sikadur AnchorFix-3 or AnchorFix-4 that was manufactured in or after January 2007 in sustained tensile-load applications, including overhead applications, where a failure of the adhesive could result in a risk to public safety, please contact David White at 201-508-6678 or Tom Zuppa at 201-508-6640.



Sika Corporation, 201 Polito Avenue, Lyndhurst NJ 07071, USA
Tel: 201 933 8800, Fax: 201 933 6225, www.sikausa.com

